

Protocol Implementation Conformance Statement
for the IEC 61850 interface in AQ-F215

UCA International Users Group
Testing Sub Committee

Template version 1.0
Date: March 25, 2008

1 General

The following ACSI conformance statements are used to provide an overview and details about Arcteq AQ-F215, with firmware v1.0.3:

- ACSI basic conformance statement,
- ACSI models conformance statement,
- ACSI service conformance statement

The statements specify the communication features mapped to IEC 61850-8-1.

2 ACSI basic conformance statement

The basic conformance statement is defined in Table A.1.

Table A.1 – Basic conformance statement

		Client/ Subscriber	Server/ Publisher	Value/ Com- ments
Client-Server roles				
B11	Server side (of TWO-PARTY-APPLICATION-ASSOCIATION)	—	Y	
B12	Client side of (TWO-PARTY-APPLICATION-ASSOCIATION)	N	—	
SCSMs supported				
B21	SCSM: IEC 6185-8-1 used	N	Y	
B22	SCSM: IEC 6185-9-1 used			
B23	SCSM: IEC 6185-9-2 used			
B24	SCSM: other			
Generic substation event model (GSE)				
B31	Publisher side	—	N	
B32	Subscriber side	N	—	
Transmission of sampled value model (SVC)				
B41	Publisher side	—	N	
B42	Subscriber side	N	—	
— Y = supported N or empty = not supported				

3 ACSI models conformance statement

The ACSI models conformance statement is defined in Table A.2.

Table A.2 – ACSI models conformance statement

		Client/ Subscriber	Server/ Publisher	Value/ Com- ments
If Server or Client side (B11/12) supported				
M1	Logical device	N	Y	
M2	Logical node	N	Y	
M3	Data	N	Y	
M4	Data set	N	Y	
M5	Substitution	N	N	
M6	Setting group control	N	N	
	Reporting			
M7	Buffered report control	N	Y	
M7-1	sequence-number	N	Y	
M7-2	report-time-stamp	N	Y	
M7-3	reason-for-inclusion	N	Y	
M7-4	data-set-name	N	Y	
M7-5	data-reference	N	Y	
M7-6	buffer-overflow	N	Y	
M7-7	entryID	N	Y	
M7-8	BufTim	N	Y	
M7-9	IntgPd	N	Y	
M7-10	GI	N	Y	
M7-11	conf-revision	N	Y	
M8	Unbuffered report control	N	Y	
M8-1	sequence-number	N	Y	
M8-2	report-time-stamp	N	Y	
M8-3	reason-for-inclusion	N	Y	
M8-4	data-set-name	N	Y	
M8-5	data-reference	N	Y	
M8-6	BufTim	N	Y	
M8-7	IntgPd	N	Y	
M8-8	GI	N	Y	
M8-9	conf-revision	N	Y	
	Logging			
M9	Log control	N	N	
M9-1	IntgPd	N	N	
M10	Log	N	N	
M11	Control	N	Y	
If GSE (B31/32) is supported				
M12	GOOSE	N	N	
M13	GSSE	N	N	
If SVC (41/42) is supported				
M14	Multicast SVC	N	N	

		Client/ Subscriber	Server/ Publisher	Value/ Com- ments
M15	Unicast SVC	N	N	
If Server or Client side (B11/12) supported				
M16	Time	N	Y	
M17	File Transfer	N	N	
Y = service is supported				
N or empty = service is not supported				

4 ACSI service conformance statement

The ACSI service conformance statement is defined in Table A.3 (depending on the statements in Table A.1).

Table A.3 – ACSI service Conformance statement

	Services	AA: TP/MC	Client (C)	Server (S)	Comments
Server					
S1	ServerDirectory	TP	N	Y	

Application association					
S2	Associate		N	Y	
S3	Abort		N	Y	
S4	Release		N	Y	

Logical device					
S5	LogicalDeviceDirectory	TP	N	Y	

Logical node					
S6	LogicalNodeDirectory	TP	N	Y	
S7	GetDataValues	TP	N	Y	

Data					
S8	GetDataValues	TP	N	Y	
S9	SetDataValues	TP	N	Y	
S10	GetDataDirectory	TP	N	Y	
S11	GetDataDefinition	TP	N	Y	

Data set					
S12	GetDataSetValues	TP	N	Y	
S13	SetDataSetValues	TP	N	N	
S14	CreateDataSet	TP	N	N	
S15	DeleteDataSet	TP	N	N	

	Services	AA: TP/MC	Client (C)	Server (S)	Comments
S16	GetDataSetDirectory	TP	N	Y	

Substitution					
S17	SetDataValues	TP	N	N	

Setting group control					
S18	SelectActiveSG	TP	N	N	
S19	SelectEditSG	TP	N	N	
S20	SetSGValues	TP	N	N	
S21	ConfirmEditSGValues	TP	N	N	
S22	GetSGValues	TP	N	N	
S23	GetSGCBValues	TP	N	N	

Reporting					
Buffered report control block (BRCB)					
S24	Report	TP	N	Y	
S24-1	data-change (dchg)		N	Y	
S24-2	qchg-change (qchg)		N	Y	
S24-3	data-update (dupd)		N	Y	
S25	GetBRCBValues	TP	N	Y	
S26	SetBRCBValues	TP	N	Y	
Unbuffered report control block (URCB)					
S27	Report	TP	N	Y	
S27-1	data-change (dchg)		N	Y	
S27-2	qchg-change (qchg)		N	Y	
S27-3	data-update (dup)		N	Y	
S28	GetURCBValues	TP	N	Y	
S29	SetURCBValues	TP	N	Y	

Logging					
Log control block					
S30	GetLCBValues	TP	N	N	
S31	SetLCBValues	TP	N	N	
Log					
S32	QueryLogByTime	TP	N	N	
S33	QueryLogByEntry	TP	N	N	
S34	GetLogStatusValues	TP	N	N	

Generic substation event model (GSE)					
GOOSE-CONTROL-BLOCK					
S35	SendGOOSEMessage	MC	N	N	

	Services	AA: TP/MC	Client (C)	Server (S)	Comments
S36	GetReference	TP	N	N	
S37	GetGOOSEElementNumber	TP	N	N	
S38	GetGoCBValues	TP	N	N	
S39	SetGoCBValues	TP	N	N	
GSSE-CONTROL-BLOCK					
S40	SendGSSEMessage	MC	N	N	
S41	GetReference	TP	N	N	
S42	GetGSSEElementNumber	TP	N	N	
S43	GetGsCBValues	TP	N	N	
S44	SetGsCBValues	TP	N	N	

Transmission of sampled value model (SVC)					
Multicast SVC					
S45	SendMSVMessage	MC	N	N	
S46	GetMSVCBValues	TP	N	N	
S47	SetMSVCBValues	TP	N	N	
Unicast SVC					
S48	SendUSVMessage	TP	N	N	
S49	GetUSVCBValues	TP	N	N	
S50	SetUSVCBValues	TP	N	N	

Control					
S51	Select		N	N	
S52	SelectWithValue	TP	N	N	
S53	Cancel	TP	N	N	
S54	Operate	TP	N	Y	
S55	Command-Termination	TP	N	N	
S56	TimeActivated-Operate	TP	N	N	

File transfer					
S57	GetFile	TP	N	N	
S58	SetFile	TP	N	N	
S59	DeleteFile	TP	N	N	
S60	GetFileAttributeValues	TP	N	N	

Time					
T1	Time resolution of internal clock			10	nearest negative power of 2 in seconds
T2	Time accuracy of internal clock				T0
				Y	T1
					T2

	Services	AA: TP/MC	Client (C)	Server (S)	Comments
					T3
					T4
					T5
T3	Supported TimeStamp resolution	-		10	nearest negative power of 2 in seconds

Instruction and comments on using this template

Comments

The template has the following differences compared to IEC 61850-7-2 Edition 1:

- inserted changes suggested for revision 2 of the standard: M7-11, M8-8, M8-9
- removed rows suggested for revision 2 : M12-1 and M12-2
- added a row identifier for M12 (GOOSE)
- all services are optional
- It's not required to include the MMS conformance statement from IEC 61850-8-1 Annex A
- Questions and comments can be e-mailed to: helpdesk@ucausersgroup.org

Instructions

- format of the document may be changed into your company format
- enter the applicable IED name and firmware version
- update the Y/N values
- for a server remove the Y/N values in the client columns
- for a client remove the Y/N values in the server columns
- remove the instructions, comments and revision history of the template

Revision history

Revision	Remarks
0.1	First version